

**Part III Form 2  
Section 11. ANNUAL REPORT.**

<b>Drinking-Water System Number:</b>	260011661
<b>Drinking-Water System Name:</b>	Morning Glory PS
<b>Drinking-Water System Owner:</b>	York Region District School Board
<b>Drinking-Water System Category:</b>	Small Non-Municipal Non-Residential
<b>Period being reported:</b>	01/04/2025 to 31/03/2026

<p><b><u>Complete if your Category is Large Municipal Residential or Small Municipal Residential</u></b></p> <p>Does your Drinking-Water System serve more than 10,000 people? Yes [ ] No [x]</p> <p>Is your annual report available to the public at no charge on a web site on the Internet? Yes [x] No [ ]</p> <p>Location where Report required under O. Reg. 170/03 Schedule 22 will be available for inspection.</p> <div style="border: 1px solid black; height: 100px; width: 100%;"></div>	<p><b><u>Complete for all other Categories.</u></b></p> <p>Number of Designated Facilities served:</p> <div style="border: 1px solid black; display: inline-block; padding: 2px 10px;">1</div> <p>Did you provide a copy of your annual report to all Designated Facilities you serve? Yes [x] No [..]</p> <p>Number of Interested Authorities you report to:</p> <div style="border: 1px solid black; display: inline-block; padding: 2px 10px;">1</div> <p>Did you provide a copy of your annual report to all Interested Authorities you report to for each Designated Facility? Yes [x] No [..]</p>
---	---

**Note: For the following tables below, additional rows or columns may be added or an appendix may be attached to the report**

**List all Drinking-Water Systems (if any), which receive all of their drinking water from your system:**

Drinking Water System Name	Drinking Water System Number
Morning Glory PS	260011661

Did you provide a copy of your annual report to all Drinking-Water System owners that are connected to you and to whom you provide all of its drinking water? Yes [x] No [..]

**Indicate how you notified system users that your annual report is available, and is free of charge.**

- Public access/notice via the web**
- Public access/notice via Government Office**
- Public access/notice via a newspaper**
- Public access/notice via Public Request**
- Public access/notice via a Public Library**
- Public access/notice via other method:**

**Describe your Drinking-Water System**

Morning Glory P.S. is served by an on-site well water supply located on the west side of the school. The original well is drilled to a depth of 14.03 metres below grade, where water is obtained from a confined clay aquifer. The new well was drilled on September 25, 2007, and is located on the west side of the school and the well is drilled to a depth of 19.0 metres below grade, where water is obtained from a confined clay aquifer. In order to comply with minimum treatment requirements, ultraviolet disinfection equipment was installed at this school (note there are 2 UV treatment systems in parallel). Filtration is provided by 5 micron cartridge filters (in parallel prior to UV). As an extra precaution, chlorine feed equipment and turbidity meter were installed even though they were not required by the regulation. In 2007 UPS power back up units were installed for the turbidity meter, chlorine analyzer, chessell recorder and UV system to provide power to the water treatment system for up to three hours in case of a power failure. Two automatic shut off valves were installed to stop water flow in the event the UV disinfection unit alarms due to loss of intensity. This prevents untreated water from being distributed to the system when the UV cannot provide an adequate level of disinfection. New UV units were installed and an updated Engineering Evaluation Report was completed August 12, 2019.

**List all water treatment chemicals used over this reporting period**

Sodium Hypochlorite (12% Chlorine solution)

**Were any significant expenses incurred to?**

- Install required equipment
- Repair required equipment
- Replace required equipment

**Please provide a brief description and a breakdown of monetary expenses incurred**

The cost to install, repair and replace required equipment, as well as the contractor to service the equipment and test the water, is approximately \$26,530.02.

**Provide details on the notices submitted in accordance with subsection 18(1) of the Safe Drinking-Water Act or section 16-4 of Schedule 16 of O.Reg.170/03 and reported to Spills Action Centre?**

Incident Date	Parameter	Result	Unit of Measure	Corrective Action	Corrective Action Date
---------------	-----------	--------	-----------------	-------------------	------------------------

**Microbiological testing done under the Schedule 10, 11 or 12 of Regulation 170/03, during this reporting period.**

	Number of Samples	Range of E.Coli or Fecal Results (min #)-(max #)	Range of Total Coliform Results (min #)-(max #)	Number of HPC Samples	Range of HPC Results (min #)-(max #)
<b>Raw</b>	13	0 - 0	0 - 0		
<b>Treated</b>	26	0 - 0	0 - 0	26	0 - 142
<b>Distribution</b>					

**Operational testing done under Schedule 7, 8 or 9 of Regulation 170/03 during the period covered by this Annual Report.**

	Number of Grab Samples	Range of Results (min #)-(max #)
<b>Turbidity</b>	n/a	n/a
<b>Chlorine</b>	n/a	n/a
<b>Fluoride</b> (If the DWS provides fluoridation)	n/a	n/a

*NOTE: For continuous monitors use 8760 as the number of samples.*

*NOTE: Record the unit of measure if it is **not** milligrams per litre.*

**Summary of additional testing and sampling carried out in accordance with the requirement of an approval, order or other legal instrument.**

Date of legal instrument issued	Parameter	Date Sampled	Result	Unit of Measure

**Summary of Inorganic parameters tested during this reporting period or the most recent sample results**

Parameter	Sample Date	Result Value	Unit of Measure	Exceedance
<b>Antimony</b>	01/02/2022	.0006	mg/L	No
<b>Arsenic</b>	01/02/2022	.0002	mg/L	No
<b>Barium</b>	01/02/2022	.053	mg/L	No
<b>Boron</b>	01/02/2022	.015	mg/L	No
<b>Cadmium</b>	01/02/2022	.000003	mg/L	No
<b>Chromium</b>	01/02/2022	.00008	mg/L	No
<b>Fluoride</b>	01/02/2022	.17	mg/L	No
<b>Lead (Flushed Sample)</b>	10/05/2025	0.0	mg/L	No
<b>Lead (Flushed Sample)</b>	10/05/2025	0.0	mg/L	No
<b>Lead (Standing)</b>	08/06/2024	.0011	mg/L	No

<b>Sample)</b>				
<b>Lead (Standing Sample)</b>	15/06/2024	.001	mg/L	No
<b>Mercury</b>	01/02/2022	.00001	mg/L	No
<b>Nitrate</b>	25/02/2025	1.67	mg/L	No
<b>Nitrate</b>	05/12/2024	2.21	mg/L	No
<b>Nitrate</b>	10/09/2024	2.29	mg/L	No
<b>Nitrate</b>	18/06/2024	1.73	mg/L	No
<b>Nitrite</b>	25/02/2025	.003	mg/L	No
<b>Nitrite</b>	05/12/2024	.003	mg/L	No
<b>Nitrite</b>	10/09/2024	.003	mg/L	No
<b>Nitrite</b>	18/06/2024	.003	mg/L	No
<b>Selenium</b>	01/02/2022	.00029	mg/L	No
<b>Sodium</b>	01/02/2022	34.8	mg/L	Yes
<b>Sodium</b>	14/02/2022	30	mg/L	Yes
<b>Uranium</b>	01/02/2022	.00263	mg/L	No

**Summary of Organic parameters sampled during this reporting period or the most recent sample results**

Parameter	Sample Date	Result Value	Unit of Measure	Exceedance
<b>1,1-Dichloroethylene</b>	01/02/2022	.00033	mg/L	No
<b>1,2-Dichlorobenzene</b>	01/02/2022	.00041	mg/L	No
<b>1,2-Dichloroethane</b>	01/02/2022	.00035	mg/L	No
<b>1,4-Dichlorobenzene</b>	01/02/2022	.00036	mg/L	No
<b>2,3,4,6-Tetrachlorophenol</b>	01/02/2022	.0002	mg/L	No
<b>2,4,6-Trichlorophenol</b>	01/02/2022	.00025	mg/L	No
<b>2,4-D</b>	01/02/2022	.00019	mg/L	No
<b>2,4-Dichlorophenol</b>	01/02/2022	.0015	mg/L	No
<b>2-methyl-4-chlorophenoxyacetic acid (MCPA)</b>	01/02/2022	.00012	mg/L	No
<b>Alachlor</b>	01/02/2022	.00002	mg/L	No
<b>Atrazine + N-dealkylated metabolites</b>	01/02/2022	.00001	mg/L	No
<b>Azinphos-methyl</b>	01/02/2022	.00005	mg/L	No
<b>Benzene</b>	01/02/2022	.00032	mg/L	No
<b>Benzo(a)pyrene</b>	01/02/2022	.000004	mg/L	No
<b>Bromoxynil</b>	01/02/2022	.00033	mg/L	No
<b>Carbaryl</b>	01/02/2022	.00005	mg/L	No
<b>Carbofuran</b>	01/02/2022	.00001	mg/L	No
<b>Carbon Tetrachloride</b>	01/02/2022	.00017	mg/L	No
<b>Chlorpyrifos</b>	01/02/2022	.00002	mg/L	No
<b>Diazinon</b>	01/02/2022	.00002	mg/L	No
<b>Dicamba</b>	01/02/2022	.0002	mg/L	No
<b>Dichloromethane</b>	01/02/2022	.00035	mg/L	No
<b>Diclofop-methyl</b>	01/02/2022	.0004	mg/L	No
<b>Dimethoate</b>	01/02/2022	.00006	mg/L	No
<b>Diquat</b>	01/02/2022	.001	mg/L	No
<b>Diuron</b>	01/02/2022	.00003	mg/L	No
<b>Glyphosate</b>	01/02/2022	.001	mg/L	No
<b>Malathion</b>	01/02/2022	.00002	mg/L	No
<b>Metolachlor</b>	01/02/2022	.00001	mg/L	No
<b>Metribuzin</b>	01/02/2022	.00002	mg/L	No

<b>Monochlorobenzene</b>	01/02/2022	.0003	mg/L	No
<b>Paraquat</b>	01/02/2022	.001	mg/L	No
<b>PCB</b>	01/02/2022	.00004	mg/L	No
<b>Pentachlorophenol</b>	01/02/2022	.00015	mg/L	No
<b>Phorate</b>	01/02/2022	.00001	mg/L	No
<b>Picloram</b>	01/02/2022	.001	mg/L	No
<b>Prometryne</b>	01/02/2022	.00003	mg/L	No
<b>Simazine</b>	01/02/2022	.00001	mg/L	No
<b>Terbufos</b>	01/02/2022	.00001	mg/L	No
<b>Tetrachloroethylene</b>	01/02/2022	.00035	mg/L	No
<b>Triallate</b>	01/02/2022	.00001	mg/L	No
<b>Trichloroethylene</b>	01/02/2022	.00044	mg/L	No
<b>Trifluralin</b>	01/02/2022	.00002	mg/L	No
<b>Vinyl Chloride</b>	01/02/2022	.00017	mg/L	No

**List any Inorganic or Organic parameter(s) that exceeded half the standard prescribed in Schedule 2 of Ontario Drinking Water Quality Standards.**

Parameter	Result Value	Unit of Measure	Date of Sample
n/a	n/a	n/a	n/a

**(Only if DWS category is large municipal residential, small municipal residential, large municipal non residential, non municipal year round residential, large non municipal non residential)**